

TOWN OF ANSON LABORATORY ANALYSIS REPORT

Parameter	Result	Date Analyzed	Health Hazard Standard
Alachlor	ND	2/6/2024	2 micrograms/liter
Aldicarb	ND		
Aldicarb sulfone	ND		
Aldicarb sulfoxide	ND		
Aldrin	ND	2/6/2024	
Antimony	ND	2/6/2024	6 micrograms/liter
Arsenic	ND	2/6/2024	10 micrograms/liter
Atrazine	ND	2/6/2024	EPA 3 microgram/liter
Barium	0.45	2/6/2024	2 milligrams/liter
Benzene	ND	2/22/2024	5 ug/l
Benzol(a)pyrene	ND	2/6/2024	0.2 ug/l
Beryllium	ND	2/6/2024	4 micrograms/liter
BHC gamma (Lindane)	ND	2/6/2024	0.2 ug/l
Bromobenzene	ND	2/22/2024	
Bromochloromethane	ND	2/22/2024	
Bromodichloromethane	ND	2/22/2024	80 ug/l
Bromoform	ND	2/22/2024	80 ug/l
Bromomethane	ND	2/22/2024	
Butachlor	ND	2/6/2024	
Cadmium	ND	2/6/2024	5 micrograms/liter
Carbaryl	ND	2/6/2024	
Carbofuran	ND	2/6/2024	40 ug/l
Carbon (Tetrachloride)	ND	2/22/2024	5 ug/l
Chlordane	ND	2/6/2024	2 micrograms/liter
Chlordane (Alpha)	ND	2/6/2024	
Chlordane (Gamma)	ND	2/6/2024	
Chlorobenzene	ND	2/22/2024	100 ug/l
Chloroethane	ND	2/22/2024	
Chloroform	ND	2/22/2024	80 ug/l
Chloromethane	ND	2/22/2024	
2-Chlorotoluene	ND	2/22/2024	
4-Chlorotoluene	ND	2/22/2024	
Chromium	ND	2/6/2024	100 micrograms/liter
Coliform Bacteria	ND	2/15/2024	
Copper	6.8	2/6/2024	1300 micrograms/liter
2,4-D	ND	2/6/2024	70 ug/l
Dalapon	ND	2/6/2024	0.2 milligrams/liter
Deethylatrazine	ND	2/6/2024	
Deisopropylatrazine	ND	2/6/2024	
Di(2-ethylhexyl) adipate	ND	2/6/2024	400 ug/l
Di(2-ethylhexyl) phthalate	ND	2/6/2024	6 ug/l
Dicamba	ND	2/6/2024	300 micrograms/liter
1,2-Dibromo-3-Chloropropane (DBCP)	ND	2/22/2024	
1,2-Dibromoethane (EDB)	ND	2/22/2024	0.05 ug/l
Dibromochloromethane	ND	2/22/2024	80 ug/l
Dibromomethane	ND	2/22/2024	
1,3-Dichlorobenzene	ND	2/22/2024	
1,2-Dichlorobenzene	ND	2/22/2024	600 ug/l
1,4-Dichlorobenzene	ND	2/22/2024	75 ug/l
Dichlorodifluoromethane	ND	2/22/2024	
1,1-Dichloroethane	ND	2/22/2024	
1,2-Dichloroethane	ND	2/22/2024	5 ug/l
1,1-Dichloroethene	ND	2/22/2024	7 ug/l
cis-1,2-Dichloroethene	ND	2/22/2024	70 ug/l
trans-1,2-Dichloroethene	ND	2/22/2024	100 ug/l
Dichloromethane	ND	2/22/2024	5 ug/l
1,2-Dichloropropane	ND	2/22/2024	5 ug/l
1,3-Dichloropropane	ND	2/22/2024	
2,2-Dichloropropene	ND	2/22/2024	
1,1-Dichloropropene	ND	2/22/2024	
1,3-Dichloropropene (Total cis+trans)	ND	2/22/2024	
Dieldrin	ND	2/6/2024	
Dinoseb	ND	2/6/2024	7 micrograms/liter
Endothall	ND	2/6/2024	0.1 parts per million
Endrin	ND	2/6/2024	2 micrograms/liter
Ethyl Benzene	ND	2/22/2024	700 ug/l
Fluoride	0.12	2/6/2024	4 milligrams/liter
Glyphosate (Round-up)	ND	2/6/2024	700 parts per billion
Heptachlor	ND	2/6/2024	0.4 micrograms/liter
Heptachlor epoxide	ND	2/6/2024	0.2 micrograms/liter
Hexachlorobenzene	ND	2/6/2024	1 microgram/liter
Hexachlorobutadiene	ND	2/22/2024	1.0 ug/l
Hexachlorocyclopentadiene	ND	2/6/2024	0.05 parts per million
3-Hydroxycarbofuran	ND	2/6/2024	
Isopropylbenzene	ND	2/22/2024	
p-Isopropylbenzene	ND	2/22/2024	
Lead	0.57	2/6/2024	15 micrograms/liter
Manganese	37	2/6/2024	50 ug/l
Mercury	ND	2/6/2024	2 micrograms/liter
Metribuzin	ND	2/6/2024	
Methomyl	ND		
Methoxychlor	ND	2/6/2024	40 micrograms/liter
Metolachlor (Dual)	ND	2/6/2024	
MTBE	ND	2/22/2024	
n-Butylbenzene	ND	2/22/2024	
n-Propylbenzene	ND	2/22/2024	
Naphthalene	ND	2/22/2024	
Nickel	1.6	2/6/2024	100 micrograms/liter
Nitrate	1	2/14/2024	10 PPM
Oxamyl	ND	2/6/2024	0.2 parts per million
PCBs	0	2/6/2024	0.5 ug/l
Pentachlorophenol	ND	2/6/2024	1 microgram/liter
Picloram	ND	2/6/2024	500 micrograms/liter
Propachlor	ND	2/6/2024	
sec-Butylbenzene	ND	2/22/2024	
Selenium	ND	2/6/2024	50 micrograms/liter
2,4,5-TP (Silvex)	ND	2/6/2024	50 ug/l
Simazine	ND	2/6/2024	4 micrograms/liter
Styrene	ND	2/22/2024	100 ug/l
tert-Butylbenzene	ND	2/22/2024	
1,1,1,2-Tetrachloroethane	ND	2/22/2024	
1,1,2,2-Tetrachloroethane	ND	2/22/2024	
Tetrachloroethene	ND	2/22/2024	5 ug/l
Toluene	ND	2/22/2024	1000 ug/l
1,2,4-Trichlorobenzene	ND	2/22/2024	70 ug/l
1,1,1-Trichloroethane	ND	2/22/2024	200 ug/l
1,1,2-Trichloroethane	ND	2/22/2024	5 ug/l
Trichloroethene	ND	2/22/2024	5 ug/l
Trichlorofluoromethane	ND	2/22/2024	
1,2,3-Trichloropropane	ND	2/22/2024	
1,2,3-Trichlorobenzene	ND	2/22/2024	
1,2,4-Trimethylbenzene	ND	2/22/2024	
1,3,5-Trimethylbenzene	ND	2/22/2024	
Thallium	ND	2/6/2024	2 micrograms/liter
Toxaphene	ND	2/6/2024	3 micrograms/liter
Turbidity screening SDWA (200.7)	ND	2/6/2024	1 NTU
Turbidity screening SDWA (200.8)	ND	2/6/2024	1 NTU
Vinyl Chloride	ND	2/22/2024	0.2 ug/l
Xylene (Total)	ND	2/22/2024	10000 ug/l

Northern Lake Service, Inc.	WI State Lab of Hygiene	Eau Claire City-County Health Dept.
Sample Site:	Sample Site: Kitchen Sink	Sample Site: Kitchen Sink
Sample Collected: 2/14/24	Sample Collected: 10/30/23	Sample Collected: 12/19/23