

TOWN OF LAFAYETTE LABORATORY ANALYSIS REPORT

Parameter	Result	Date Analyzed	Health Hazard Standard
Acesulfame	13100	11/9/2022	
Acetamiprid	1.7	11/9/2022	
Alachlor (ESA and OA)	0.08	11/9/2022	2 micrograms/liter
Alkalinity	34	8/28/2023	
Atrazine (Aatrex)	ND	5/22/2023	EPA 3 microgram/liter
Caffeine	12	11/9/2022	
Carbamazepine	7.6	11/9/2022	
Chloride	148 mg/l	8/28/2023	
Clothianidin	1.5	11/9/2022	
Coliform Bacteria	ND	4/24/2024	
Cond-fld (uS/CM@25C)	250	11/9/2024	
Conductivity	629 umhos/cm	8/28/2023	
Dinotefuran	0.7	11/9/2022	
Hardness	197 mg/l	8/28/2023	
Imidacloprid	2.4	11/9/2022	
Metolachlor (ESA & OA)	0.08	11/9/2022	
Nitrate	6.52	1/3/2024	10 PPM
Paraxanthine	5	11/9/2022	
PFAS			
-DONA	<0.120	11/9/2024	
-FDUEA	<0.344	11/9/2024	
-FHpPA	<0.414	11/9/2024	
-FHUEA	<0.271	11/9/2024	
-FOSA	<0.146	11/9/2024	
-FOUEA	<0.205	11/9/2024	
-FPePA	<0.364	11/9/2024	
-FPrPA	<0.235	11/9/2024	
-HFPO-DA	<0.180	11/9/2024	
-N-EtFOSA	<0.652	11/9/2024	
-N-EtFOSAA	<0.199	11/9/2024	
-N-EtFOSE	<0.940	11/9/2024	
-N-MeFOSA	<0.940	11/9/2024	
-N-MeFOSAA	<0.206	11/9/2024	
-N-MeFOSE	<0.264	11/9/2024	
-PFBA	3.36	11/9/2024	
-PFBS	2.82	11/9/2024	
-PFBSA	<0.406	11/9/2024	
-PFDoA	<0.255	11/9/2024	
-PFDoS	<0.374	11/9/2024	
-PFDS	<0.242	11/9/2024	
-PFECBS	<0.180	11/9/2024	
-PFHpA	1.65	11/9/2024	
-PFHpS	<0.179	11/9/2024	
-PFHxA	7.01	11/9/2024	
-PFHxS	1.27	11/9/2024	
-PFHxSA	<0.455	11/9/2024	
-PFNA	0.237F	11/9/2024	
-PFNS	<0.171	11/9/2024	
-PFOA	6.14	11/9/2024	
-PFOS	2.03	11/9/2024	
-PFPeA	3.28	11/9/2024	
-PFPeS	0.133F	11/9/2024	
-PFPrS	<0.235	11/9/2024	
-PFSA	<0.153	11/9/2024	
-PFTeDA	<0.164	11/9/2024	
-PFTrDA	<0.181	11/9/2024	
-PFUnA	<0.209	11/9/2024	
-4:2 FTSA	<0.179	11/9/2024	
-6:2 FTSA	<0.256	11/9/2024	
-8:2 FTSA	<0.246	11/9/2024	
-9CI-PF3ONS	<0.171	11/9/2024	
-10:2 FTSA	<0.193	11/9/2024	
-11CI-PF3OUdS	<0.140	11/9/2024	
pH	7.63	8/28/2023	500 micrograms/liter
Sucralose	16100	11/9/2022	
Sulfamethoxazole	171	11/9/2022	
Thiamethoxam	1.5	11/9/2022	

Chippewa County Public Health	WI State Lab of Hygiene	Commerical Testing Laboratory
Sample Site: Well Sample Tap	Sample Site: Kitchen Sink	Sample Site: Kitchen Tap
Sample Collected: 4/24/24	Sample Collected: 11/9/22	Sample Collected: 1/3/24

UW-Stevens Point Water Analysis Lab
Sample Site:
Sample Collected: 11/9/22