

TOWN OF WHEATON LABORATORY ANALYSIS REPORT

Parameter	Result	Date Analyzed	Health Hazard Standard
Alachlor	<0.0053	11/13/2023	2 micrograms/liter
Antimony	1.58F	11/7/2023	6 micrograms/liter
Arsenic	ND	11/2/2023	10 micrograms/liter
Atrazine	<0.0061	11/13/2023	EPA 3 microgram/liter
Atrazine (Aatrex)	ND	6/28/2023	EPA 3 microgram/liter
Barium	4.96	11/6/2023	2 milligrams/liter
Beryllium	ND	11/6/2023	4 micrograms/liter
Cadmium	0.0340F	11/7/2023	5 micrograms/liter
Carbofuran	<0.28	11/17/2023	40 micrograms/liter
Chlordane	<0.20	11/7/2023	2 micrograms/liter
Chromium	ND	11/1/2023	100 micrograms/liter
Coliform Bacteria	ND	5/16/2023	
Copper	2050	11/6/2023	1300 micrograms/liter
Dalapon	<0.93	11/9/2023	0.2 milligrams/liter
Dicamba	<0.15	11/9/2023	300 micrograms/liter
2, 4-Dichlorophenoxyacetic acid	<0.10	11/9/2023	70 micrograms/liter
Dinoseb	<0.15	11/9/2023	7 micrograms/liter
Diquat	<0.34	11/8/2023	0.02 milligrams/liter
Endothall	<1.5	11/8/2023	0.1 parts per million
Endrin	<0.0081	11/13/2023	2 micrograms/liter
Fluoride	0.0785F	10/31/2023	4 milligrams/liter
gamma-BHC (Lindane)	<0.0049	11/13/2023	0.2 micrograms/liter
Glyphosate (Round-up)	<3	11/10/2023	700 parts per billion
Heptachlor	<0.0047	11/13/2023	0.4 micrograms/liter
Heptachlor epoxide	<0.013	11/13/2023	0.2 micrograms/liter
Hexachlorobenzene	<0.0048	11/13/2023	1 microgram/liter
Hexachlorocyclopentadiene	<0.026	11/13/2023	0.05 parts per million
Lead	0.17	12/21/2023	15 micrograms/liter
Lead	0.564F	11/20/2023	15 micrograms/liter
Manganese	2.64	11/6/2023	300 micrograms/liter
Mercury	ND	11/9/2023	2 micrograms/liter
Methoxychlor	<0.0095	11/13/2023	40 micrograms/liter
Nickel	4.64	11/6/2023	100 micrograms/liter
Nitrate	2.9	5/16/2023	10 PPM
Oxamyl	<0.24	11/17/2023	0.2 parts per million
Pentachlorophenol	<0.04	11/9/2023	1 microgram/liter
PFAS			
-PFBS	0.232 ng/l	6/19/2023	
-PFHxS	0.252 ng/l	6/19/2023	
-FOSA	0.22 ng/l	6/19/2023	
Picloram	<0.10	11/9/2023	500 micrograms/liter
Selenium	ND	11/1/2023	50 micrograms/liter
Simazine	<0.0062	11/13/2023	4 micrograms/liter
Thallium	ND	11/1/2023	2 micrograms/liter
Toxaphene	<0.80	11/7/2023	3 micrograms/liter

Davy Laboratories, La Crosse, WI	WI State Lab of Hygiene	Eau Claire City-County Health Dept.
Sample Site: Kitchen	Sample Site: Kitchen Sink	Sample Site: Kitchen Sink
Sample Collected: 10/30/23	Sample Collected: 10/30/23	Sample Collected: 12/19/23